

Abstract

The sources of non-self connection to the grid and non-linear loads produces high harmonic currents. This paper presents a study of a harmonic compensation system and reactive disturbances using a photovoltaic generator. The system consists of a voltage inverter which acts as an active filter and a photovoltaic generator parallel as a source of electrical energy. The main simulation and principal results are presented